



TEST REPORT

TEST REPORT NO E-838

Page 2 of 2

DETAILS OF TESTS:

Sl. No.	Name of Test	Specified values	Actual Results	Remarks
1.	Deep Discharge Cut-Off Test:-	After full charge of Emergency light switch off the main supply and ON the emergency light. The emergency light should be Off At 11.5 V +/- 10 % (Battery voltage)	Cut - off at 11.54 V	Passed
2.	Moisture Resistance Test:- (Test method adopted as per IS:302 -79)	After conditioning the emergency light At 95 % R.H. at 40 +/- 5 Deg.C. For 24 hrs.The light should be work satisfactorily.	After the test emergency light work satisfactorily	Passed

Remark: The sample conforms as per customer specification with respect to the above tests performed.

Note:

1. The test result indicated in this test report pertains only to the particular sample (s) submitted for test(s).
2. This report shall not be reproduced in any form, in parts or full, without prior written permission of this center.



सत्यमेव जयते

APPROVED BY

Brahm Prakash
01/02/07

(BRAHM PRAKASH)
ASSTT. DIRECTOR (ELECT.)

भारत सरकार
लघु उद्योग मंत्रालय
क्षेत्रीय परीक्षण केन्द्र (उ. क्षे.)